

# ***Errata to***

# **Procedural Standard for Technical Retro-Commissioning of Existing Buildings - 2019**

# **Third Edition**

Correction Sheet #1  
Issued 01 July 2022

Copyright © 2022 by NEBB®

All rights reserved. Published 2022. Printed in the United States of America. These correction sheets may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. These correction sheets may not be sold, licensed, or otherwise distributed for any commercial purposes whatsoever. The content of these correction sheets may not be modified

The corrections listed on this errata sheet apply to copies of ANSI/NEBB Standards S210-2019, Third Edition, Technical Retro-Commissioning of Existing Buildings – 2019.

## **Erratum #1**

Page 27, Section 20.2, RCx Report states:

20.2. RCx Report

The report shall include the following:

- a. Title page,
- b. Certification Page
- c. Executive summary,
- d. Details of each recommendation,
- e. RCx plan,
- f. Preliminary energy analysis,
- g. CFR,
- h. Quick fix and deferred maintenance improvement report,
- i. Assessment reports,
- j. Facility operating guide,
- k. Training records, and
- l. Testing documentation.

Page 27, Section 20.2, RCx Report, add the following:

- m. The Final Report must contain a summary list of all instrumentation and equipment used on the project accompanied by copies of the current calibration certificates.**