

Errata to **Procedural Standard for Testing, Adjusting and Balancing of Environmental Systems – 2019 Ninth Edition**

Correction Sheet #1
Issued 01 July 2022

Copyright © 2022 by NEBB®

All rights reserved. Published 2022. Printed in the United States of America. These correction sheets may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. These correction sheets may not be sold, licensed, or otherwise distributed for any commercial purposes whatsoever. The content of these correction sheets may not be modified

The correction listed on this errata sheet applies to copies of Procedural Standard for Testing, Adjusting and Balancing of Environmental Systems, Ninth Edition - 2019.

Erratum #1

Page 14, subsection 5.2.6, Instrument calibration states:

5.2.6 Instrument Calibration

This is a listing of the instruments that were used on the project or will be used to verify the reported data including instrument type, manufacturer, model number, serial number, and calibration data.

Page 14, subsection 5.2.6., Instrument Calibration was changed to the following:

5.2.6 Instrument Calibration

The Final Report must contain a summary list of all instrumentation and equipment used on the project or will be used to verify reported data, accompanied by copies of the current calibration certificates.