

Discipline Function		FHT Required Instrumentation (Effective January 1, 2023)															Notes	Calibration Requirements		
		RANGE					ACCURACY					RESOLUTION								
Air	FHT Air Velocity	25	fpm	to	2500	fpm	±	3%	of reading	±	3	fpm	1	fpm					12 Months	
		0.10	m/s	to	12.7	m/s	±	3%	of reading	±	0.02	m/s	0.01	m/s						
FHT Instruments	Tracer gas Detector	Minimum detection range: 0.01 PPM Minimum response time: 1 second The units shall be configured to measure sulfur hexafluoride (SF6), or other approved tracer gas, and display in concentration measurement units (PPM)					±	10%	of reading	or	0.025	ppm	0.01	ppm					12 Months	
	Detection Calibrator	Device used to calibrate the detection instrument in accordance with the manufacturer's specifications.					Not Applicable					Not Applicable						12 Months When Required		
	Local Challenge Source	Device that can generate a small relatively neutrally buoyant smoke, discharging with minimal velocity.					Not Applicable					Not Applicable						Not Required		
	Large Challenge Source	Device that can generate a large relatively neutrally buoyant smoke, discharging with minimal velocity.					Not Applicable					Not Applicable						Not Required		
	Ejector w/critical orifice	Shall conform to the requirements as indicated in the current edition of NEBB FHT PS. See appendix D for instrument specifications					Not Applicable					Not Applicable						Not Required		
	Orifice Calibrator	Flow Meter	0	l/m	to	10	l/m	±	3%					0.1	l/m				*2	Calibrate to appropriate tracer gas
		Mechanical Device	0	l/m	to	15	l/m	±	0.1	l/m				0.1	l/m					12 Months
	Tracer Gas	Sulfur Hexafluoride Commercial grade (Minimum purity of 99%) or approved replacement gas					Not Applicable					Not Applicable						SDS Required		
Mannequin	A three dimensional mannequin (torso) with arms and shall be of reasonable human proportions and be clothed with a lab coat. The height must be adjustable to meet the height requirements of the various hood configurations; i.e. standard bench hood, ADA height, floor mounted, etc. Probe shall be placed in the normal breathing zone based on the various heights.					Not Applicable					Not Applicable						Not Required			

NOTES

- *1 CPT Option - choose only Option 1 OR Option 2 - along with required instrument for CPT certification (All instruments in any of the chosen is required)
- *2 FHT Orifice Calibrator - Choose only one.
- *3 Refer to Appendix A for complete instrumentation requirements for Sound Measurement (SM)
- *4 Firms may own or rent vibration equipment instrumentation for vibration certification
- *5 Calibration Requirement: Data logger calibration may be verified from a calibrated instrument with an associated calibration form showing calibration readings from both the calibrated instrument and the data logger. If a data logger is out of calibration and cannot be adjusted, the logger must be sent back to the factory for re-calibration or be replaced
- *6 Accuracy of an instrument is either stated as a percentage of full scale or as a percentage of the reading. NEBB has chosen percentage of reading due to it being a more accurate reading. Since a % of reading error becomes smaller as you read near the lowest part of the scale the instrument resolution and accuracy must be very small to maintain the accuracy of the reading. To overcome this the manufactures add a standard offset to the % of reading to maintain a reasonable accuracy at all locations on the scale. Normally for TAB readings we are never operating at the extreme ends of the scale so this has no impact on our work.
- *7 Calibrated per Industry/Manufacturer standards.
- *8 Firms may own or rent Temp Documentation Thermal Camera for RCx. BET Temp Documentation Thermal Camera must be owned.

**General Note:
Calibration Requirement:**

Some local jurisdictions require qualified electrician for any electrical readings
Instruments require a 3-point calibration, traceable to National Institute of Standards and Technology (NIST) or National Metrology Institute (NMI) unless otherwise noted.