

Discipline / Function		NEBB Instrument Master List (Effective January 1, 2023)														BET	B5C	CPT	FHT	RCx	Sound	TAB	Vibration	Notes	Calibration Requirements
		RANGE				ACCURACY				RESOLUTION															
Air	Air Pressure	0	in wg	to	10	in wg	±	2%	of reading	±	0.001	in wg	0.001	in wg	<	1	in wg	x	x	x	x	x		12 Months	
		0.01	in wg	>	1	in wg																			
		0	Pa	to	2500	Pa	±	2%	of reading	±	0.25	Pa	0.10	Pa	<	250	Pa	x	x						
		1.0	Pa	>	250	Pa																			
	Air Velocity Instrument for Pitot Traverse	100	fpm	to	3500	fpm	±	5%	of reading	±	7	fpm	1	fpm				x	x	x	x	x			12 Months
FHT Air Velocity	0.50	m/s	to	20	m/s	±	5%	of reading	±	0.04	m/s	0.01	m/s												
	25	fpm	to	2500	fpm	±	3%	of reading	±	3	fpm	1	fpm					x						12 Months	
Digital Direct Reading Hood	0.10	m/s	to	12.7	m/s	±	3%	of reading	±	0.02	m/s	0.01	m/s												
	100	cfm	to	2000	cfm	±	5%	of reading	±	7	cfm	1	cfm				x	x	x	x				12 Months	
	50	l/s	to	944	l/s	±	5%	of reading	±	4	l/s	1	l/s												
	Air Meter with probe	0	°F	to	200	°F	±	0.5%	of reading	+	2.0	°F	0.1	°F				x	x		x	x			12 Months
-20		°C	to	100	°C	±	0.5%	of reading	+	1.0	°C	0.1	°C												
Immersion Meter with probe	0	°F	to	200	°F	±	0.5%	of reading	+	2.0	°F	0.1	°F				x			x	x			12 Months	
	-20	°C	to	100	°C	±	0.5%	of reading	+	1.0	°C	0.1	°C												
Humidity	Humidity Meter (w/Probe, if req'd)	10	% RH	to	90	% RH	±	3%	RH			1%					x			x	x			12 Months	
Electrical	Amperage Measurement	0.1	AC Ampere	to	100	AC Amperes	±	2%	of reading	±	5	digits	0.1	AC Ampere				x			x	x		12 Months	
	Voltage Meter - True RMS	1	VAC	to	600	VAC	±	2%	of reading	±	5	digits	1	Volt										12 Months	
Rotation	Rotation Measurement	60	rpm	to	5000	rpm	±	2%	of reading	±	2	rpm	1	rpm				x			x	x		12 Months	
Hydronic	Pressure Measurement	0.4	psi	to	200	psi	±	2%	of reading	±	1	psi	0.1	psi				x			x	x		12 Months	
		3	kPa	to	1400	kPa	±	2%	of reading	±	7	kPa	1.0	kPa											
	Δ Pressure measurement	0.4	psi	to	75	psi	±	2%	of reading	±	0.5	psi	0.01	psi				x			x	x		12 Months	
		3	kPa	to	500	kPa	±	2%	of reading	±	3.5	kPa	0.1	kPa											
RCx Instruments	Receptacle Circuit Tester	125	VAC					Not Applicable				Not Applicable								x				Not Required	
	Voltage Detector	50	VAC	to	1000	VAC		Not Applicable				Not Applicable										x			Not Required
	Light Level Measurement	0	FC	to	4000	FC	±	3%	of reading	+	5%	full scale	0.1	FC								x			Per Manufacturer's Requirements
0		lx	to	40000	lx	±	3%	of reading	+	5%	full scale	1.0	lx												
BET / RCx Instruments	Temp Documentation Thermal Camera	-4	°F	to	450	°F	±	2%		or	3.6	°F	0.1 @ 86 °F		&	160 x 120		x						*8	Per Manufacturer's Requirements
		-20	°C	to	232	°C	±	2%		or	2.0°C	°C	0.1 @ 30 °C		&	160 x 120									

Discipline Function		NEBB Instrument Master List (Effective January 1, 2023)													BET	BSC	CPT	FIBT	RCx	Sound	TAB	Vibration	Notes	Calibration Requirements			
		RANGE					ACCURACY					RESOLUTION															
Data Loggers	Carbon Dioxide CO ₂	0	ppm	to	2500	ppm	±	5%	of reading	±	50	ppm	1	ppm						x	Qty = 1	Per Manufacturer's Requirements					
	Carbon Monoxide CO	0	ppm	to	1000	ppm	±	10%	of reading	±	3	ppm	1	ppm							x	Qty = 1	Per Manufacturer's Requirements				
	Lighting Levels	0	FC	to	3000	FC	±	10	FC				2	FC									Qty = 1	See Note 5			
		0	lx	to	30000	lx	±	100	lx				0	lx													
	Electrical	0	VAC	to	600	VAC		2%	of reading			VAC	1.0	VAC										Qty = 2	See Note 5		
		0	Amperes	to	100	Amperes		4%	of reading			Ampere	0.1	Ampere													
	Static Pressure - Low	0	in wc	to	0.25	in wc	±	1%	full scale				0.01	in wc	<	1	in wc										
													0.1	in wc	>	1	in wc										
		0	Pa	to	60	Pa	±	1%	full scale				2.5	Pa	<	250	Pa										
	Static Pressure - High																										
0		in wc	to	6.00	in wc	±	1%	full scale				0.01	in wc	<	1	in wc											
													0.1	in wc	>	1	in wc										
Water Pressure	0	psi	to	100	psi	±	1%	of reading	psi			1.0	psi											Qty = 1	See Note 5		
	0	kPa	to	700	kPa	±	1%	of reading	kPa			0.1	kPa														
Temperature	-4	°F	to	150	°F	±	0.63	°F	@	32-122	°F	0.05	°F	@	77	°F								Qty = 8	See Note 5		
	-20	°C	to	65	°C	±	0.35	°C	@	0-50	°C	0.03	°C	@	25	°C											
Humidity	10	% RH	to	90	% RH		2.5%	RH				1%	RH											Qty = 8	See Note 5		
Event	Not Applicable					Not Applicable					Not Applicable													Qty = 2	Not required		
RCx Instruments	Thermal Infrared Thermometer	-4	°F	to	500	°F	±	2%	of reading	±	4	°F	0.5	°F												Per Manufacturer's Requirements	
		-20	°C	to	260	°C	±	2%	of reading	±	2	°C	0.2	°C													
	TDS Meter	0	μ	to	1000	μ	±	2%	full scale				1.0%														Per Manufacturer's Requirements
0		ppm	to	1000	ppm	±	2%	full scale																			
Capacitance Moisture Meter	0%		to	100%		±	5%					0.75	inches	Penetration												Per Manufacturer's Requirements	
CPT Instruments	Particle Counter	A light scattering instrument with display or recording means to count and size discrete particles in air, as defined by ASTM F50-07. Instruments of this type shall provide for a minimum sampling flow rate of 28.3 L/min (1.0 cfm) and a threshold size discrimination of a minimum of 0.3 micrometer in size.																							x	*7	12 Months

Discipline		NEBB Instrument Master List (Effective January 1, 2023)										BET	BSC	CPT	FHT	RCx	Sound	TAB	Vibration	Notes	Calibration Requirements							
		RANGE	ACCURACY				RESOLUTION																					
Function																												
CPT Option 1	Aerosol Photometer	CHOOSE ONLY 1 OF THE 2 OPTIONS	The instrument shall have a threshold sensitivity of 10 ⁻³ micrograms/liter of challenge aerosol particles and be capable of measuring concentrations over a range of 105 times the threshold sensitivity. Sample flow rate shall be 28.3 L/min (1 cfm). Readout shall be either linear with an accuracy of 1% of full scale of the selected range. ± 2% of reading ± 0.1 psi 0.04 psi (US)																			*1 & *7	12 Months or 400 operating hours					
	Pneumatic Aerosol Generator		A device that can aerosolize oil medium to serve as an artificial challenge for filter integrity testing of systems under 3,000 cfm, typically Laskin nozzle(s) type, thermal generator, atomizer, etc.																				*1	Not Required				
	Thermal Aerosol Generator		A device that can aerosolize oil medium to serve as an artificial challenge for filter integrity testing of systems of 3,000 to 60,000 cfm																					*1	Not Required			
CPT Option 2	Optical Particle Counter for Scan Test		A particle counter should have a 1.0 cfm flow rate with a threshold sensitivity of at least 0.3µm. The counter must have an audible alarm for every particle that is counted. The particle counter shall have a continuous counting mode or a sample time that exceeds the time required to completely scan the area of the filter under test. This counter may also be used for Cleanliness Classification above.																				*1 & *7	12 Months				
	Diluter		A device used with the scanning particle counter to sample the aerosol challenge upstream of a filter under test. The dilution ratio shall be between 300 – 1,000:1. The resulting counts after dilution should not exceed 100,000 particles.																					*1	12 Months			
	Aerosol Generator		A device that can aerosolize oil or microsphere medium to serve as an artificial challenge for filter integrity testing. A low output (defined as one which supplies of < 5 x 10 ⁻⁹ particles /min of ≥ 0.3 um in size) or a normal output generator may be used.																					*1	Not Required			
FHT Instruments	Tracer gas Detector	Minimum detection range: 0.01 PPM Minimum response time: 1 second The units shall be configured to measure sulfur hexafluoride (SF6), or other approved tracer gas, and display in concentration measurement units (PPM)				±	10%	of reading	or	0.025	ppm	0.01	ppm									x		12 Months				
	Detection Calibrator	Device used to calibrate the detection instrument in accordance with the manufacturer's specifications.				Not Applicable				Not Applicable													x		12 Months When Required			
	Local Challenge Source	Device that can generate a small relatively neutrally buoyant smoke, discharging with minimal velocity.				Not Applicable				Not Applicable														x		Not Required		
	Large Challenge Source	Device that can generate a large relatively neutrally buoyant smoke, discharging with minimal velocity.				Not Applicable				Not Applicable															x		Not Required	
	Ejector w/critical orifice	Shall conform to the requirements as indicated in the current edition of NEBB FHT PS. See appendix D for instrument specifications				Not Applicable				Not Applicable															x		Not Required	
	Orifice Calibrator	Flow Meter	0	l/m	to	10	l/m	±	3%				0.1	l/m											x	*2	Calibrate to appropriate tracer gas	
		Mechanical Device	0	l/m	to	15	l/m	±	0.1	l/m			0.1	l/m														12 Months
	Tracer Gas	Sulfur Hexafluoride Commercial grade (Minimum purity of 99%) or approved replacement gas				Not Applicable				Not Applicable																x		SDS Required
Mannequin	A three dimensional mannequin (torso) with arms and shall be of reasonable human proportions and be clothed with a lab coat. The height must be adjustable to meet the height requirements of the various hood configurations; i.e. standard bench hood, ADA height, floor mounted, etc. Probe shall be placed in the normal breathing zone based on the various heights.				Not Applicable				Not Applicable																	x		Not Required
BET Instruments	Digital pressure flow measurement system	Not Applicable				±	4%	of reading				0.1 Pa (0.0004 inwc, 0.002 psf)														x		Per Manufacturer's Requirements

Discipline		NEBB Instrument Master List (Effective January 1, 2023)						BET	BSC	CPT	FHT	RCx	Sound	TAB	Vibration	Notes	Calibration Requirements		
		Function	RANGE		ACCURACY	RESOLUTION													
Sound Instruments	Sound Level Meter, Real Time Analyzer, & Octave Band Analyzer	Sound Level Meters (SLM's) and Real Time Analyzers	As listed in Table 3-1.2.1, 3-1.2.2 and 3-1.2.3 which conforms to Type 1 or Type 2 requirements specified in ANSI S1.4		which conforms Appendix A of the NEBB Instrument List														
		Real Time Analyzers	As listed in table 3-1.2.1 and 3-1.2.3 (which conforms to Type 1 or Type 2 requirements ANSI S1.4 and S1.11)		which conforms Appendix A of the NEBB Instrument List							x				#3	12 Months		
		Full Octave Filters	As listed in table 3-1.2.2 and 3-1.2.3 (which conforms with ANSI S1.11 Specification for Octave-Band and Fractional-Octave-Band Analog & Digital Filters		which conforms Appendix A of the NEBB Instrument List														
	Acoustic Calibrator	As listed in Table 3-1.1 (which conforms to ANSI S1.40 Specification for Acoustical Calibrators											x			#3	12 Months		
Vibration Instruments	Vibration Analyzer / Meter, Real Time Analyzer & Spectrum Analyzer	Shall meet the minimum requirements as specified below:																	
		Displacement – 0.1 to 100 mils (0.0001 to 0.1 inches)																	
		Velocity – 0.0005 to 10 in/sec																	
		Acceleration – 0.0001 to 30 G's																	
		Frequency Range – 1 to 1000 Hz (60 to 60,000 RPM)																	
		Frequency Resolution (bandwidth) – at least 1.25 Hz (1 / 75 RPM) Minimum																	
		Lines of resolution ≥ 800																	
		Detection - Peak, Peak-to-Peak, RMS																	
		FFT Windowing- Hanning at least																	
		Averaging – exponential or time and selectable to at least four averages																	
Accelerometers / Transducer		Shall have the following minimum specifications:																	
		Sensitivity (± 20%) ≥ 100 mV/G typical																	
		Measurement Range = ± 20 G peak																	
		Frequency Range = 2 to 3000 Hz at ± 3dB																	
NOTES																			
*1	CPT Option - choose only Option 1 OR Option 2 - along with required instrument for CPT certification (All instruments in any of the chosen is required)																		
*2	FHT Orifice Calibrator - Choose only one.																		
*3	Refer to Appendix A for complete instrumentation requirements for Sound Measurement (SM)																		
*4	Firms may own or rent vibration equipment instrumentation for vibration certification																		
*5	Calibration Requirement: Data logger calibration may be verified from a calibrated instrument with an associated calibration form showing calibration readings from both the calibrated instrument and the data logger. If a data logger is out of calibration and cannot be adjusted, the logger must be sent back to the factory for re-calibration or be replaced																		
*6	Accuracy of an instrument is either stated as a percentage of full scale or as a percentage of the reading. NEBB has chosen percentage of reading due to it being a more accurate reading. Since a % of reading error becomes smaller as you read near the lowest part of the scale the instrument resolution and accuracy must be very small to maintain the accuracy of the reading. To overcome this the manufactures add a standard offset to the % of reading to maintain a reasonable accuracy at all locations on the scale. Normally for TAB readings we are never operating at the extreme ends of the scale so this has no impact on our work.																		
*7	Calibrated per Industry/Manufacturer standards.																		
*8	Firms may own or rent Temp Documentation Thermal Camera for RCx. BET Temp Documentation Thermal Camera must be owned.																		
General Note:	Some local jurisdictions require qualified electrician for any electrical readings																		
Calibration Requirement:	Instruments require a 3-point calibration, traceable to National Institute of Standards and Technology (NIST) or National Metrology Institute (NMI) unless otherwise noted.																		